## **2022 Smoke Alarm Legislation flow chart** Is the building a class 1a NO **YES** and/or class 2? Does the site have existing The site does not require NO smoke alarms? smoke alarms as outlined under the smoke alarm Legislation for 2022. Does the site have AS1670 smoke detection? YES Are the alarms installed as per NO YES the 2022 legislation guidlines Are the detectors spaced as per Clause 3 of the BCA? **YES** NO The site does requires smoke alarms as per the 2022 legislation guidlines No action NO YES required Smoke alarms OR new smoke detectors are required to be No action installed as per the location Smoke alarms are required to required of Clause 3 of the BCA and the be installed as per the 2022 2022 Smoke Alarm Legislation **Smoke Alarm Legislation**