

Start: Storage Unit Sprinkler Checklist

Is the storage unit a 'rectangular shape'?

Is unit LESS THAN 800mm wide?

Is there 150mm clear space on ALL sides?

Is ANY part closer than 500mm to a sprinkler head?

Is TOP of unit greater than 500mm from sprinkler?

Code violation: Relocate unit or consult Auscoast Fire Services

Likely requires sprinklers beneath

Too close: May need relocation or additional heads

Placement likely acceptable

